



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA192634

**Certificate Holder:** Jiangsu Goodwe Power Supply Technology Co., Ltd.  
No. 90 ZiJin Road, New District,  
Suzhou, 215011,  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** Grid-connected PV Inverter  
**Trade Name:** GOODWE  
**Model No.:** GW36K-MT  
**Markings:** Input: MPP Voltage range: 200-950Vdc,  
Max 1100Vdc, 25/25/25A  
Isc 31.3/31.3/31.3A  
Output: 3/N/PE 400V~ 50/60Hz, Max 53.3A, 36kVA  
-30°C to +60°C, Class I, IP65

**Standard:** IEC 62109-1 Ed. 1.0  
IEC 62109-2 Ed. 1.0  
AS/NZS 4777.2:2015

**Conditions:** Nil

**Certification Mark:** SAA192634 or RCM

**Date First Registered:** 19 December 2019

**Date of Expiry:** 19 December 2024

*R.A. Hill*

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 19-12-19 192634/1



A P P R O V A L S ®

# Certificate of Suitability

## \* Addendum \*

**Certificate No.:** SAA192634

**Date of Issue:** 19 December 2019

**Class Description:** Non-Declared

**Product Description:** Grid-connected PV Inverter

**General Modification:**

Hardware: 290-10066

Software: V1.01.01.01

Additional Models	Trade Name	Rating
GW25K-MT	GOODWE	Input: MPP Voltage range: 200-950Vdc, Max 1100Vdc, 25/25/25A Isc 31.3/31.3/31.3A Output: 3/N/PE 400V~ 50/60Hz, Max 40A, 27.5kVA
GW29.9K-MT	GOODWE	Input: MPP Voltage range: 200-950Vdc, Max 1100Vdc, 25/25/25A Isc 31.3/31.3/31.3A Output: 3/N/PE 400V~ 50/60Hz, Max 43.3A, 29.9kVA

*R.A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 23-12-19 192634/2a  
Correction to Model No. and Rating